

TOWN OF WELLESLEY



MASSACHUSETTS

RECEIVED
TOWN CLERK'S OFFICE
WELLESLEY MA 02482

2001 JUL 11 A 8:11

ZONING BOARD OF APPEALS

TOWN HALL • 525 WASHINGTON STREET • WELLESLEY, MA 02482-5992

KENDALL P. BATES, CHAIRMAN
WILLIAM E. POLLETTA, VICE CHAIRMAN
RICHARD L. SEEGEL

ELLEN D. GORDON
EXECUTIVE SECRETARY
TELEPHONE
(781) 431-1019 EXT. 208

ROBERT A BASTILLE
CYNTHIA S. HIBBARD
ROBERT W. LEVY

ZBA 2001-40
Petition of Babson College
Publisher's Hall Parking Lot
Babson College Campus

Pursuant to due notice, the Special Permit Granting Authority held a Public Hearing on Thursday, June 14, 2001 at 7:30 p.m. in the Selectmen's Meeting Room, (Conference Room B) at the Town Hall, 525 Washington Street, Wellesley, on the petition of BABSON COLLEGE requesting Site Plan Approval pursuant to the provisions of Section XVIA, Section XIVE and Section XXV of the Zoning Bylaw for construction of PUBLISHER'S HALL PARKING LOT, a 26,850 square foot temporary parking lot containing 70 parking spaces on the BABSON COLLEGE CAMPUS, in an Educational District and a Water Supply Protection District, for use from August 1, 2001 to December 1, 2001 Restoration of the 26,850 square foot lot to grassed area shall be done in Spring 2002

On May 16, 2001, the petitioner filed a request for a hearing before this Authority, and thereafter, due notice of the hearing was given by mailing and publication.

Presenting the case at the hearing was Pamela Goldberg, Director of Business Affairs, said that Babson has done a Campus Parking Study to give the Board an overview of all the parking lots including the Publisher's Hall Parking Lot. When the fall semester begins, the CEE parking structure will not be completed. As a result, they will be close to 300 spaces short for campus parking.

Ms. Goldberg introduced Shelley Kaplan, Associate Vice President of Facilities Management & Planning; Kris Kolligian, Director of the Office of Project Management; Greg Valiton, P.E. of Andrews Survey & Engineering; and Carl King, attorney from Schnader Harrison Goldstein & Manello.

Storm Water System Discussion

Ms. Goldberg said the college is studying its various infrastructure pieces. They have completed a review of their stormwater system. Mr. Kaplan said they have recently reviewed the status of their Stormwater Management Plans with the Town Engineers. Preliminary plans involve replacement of over 13,000 feet of pipe line and several detention basins. Construction design plans will be available within 6-8 weeks. The Near Term Project Listing of the Campus Facilities Plan shows the stormwater integration systems along Wellesley Avenue and College Drive. As part of the stormwater upgrade, the water sheeting that occurs on Wellesley Avenue will be addressed with new piping and swales.

ZBA 2001-40
Petition of Babson College
Publisher's Hall Parking Lot
Babson College Campus

RECEIVED
TOWN CLERK'S OFFICE
WELLESLEY MA 02482

2001 JUL 11 A 8:11

Parking Lot Study Discussion

Mr. Kaplan said that in developing the Parking Study, TEPP did an actual count of the cars on campus every 15 minutes over a daylong period in December. Presently, there are 2,144 spaces. The count showed that they exceed practical capacity (85% of physical capacity) between 10 a.m. and 4 p.m. on weekdays. "Practical capacity" is the level at which people can find parking spaces within a reasonable amount of time. The peak was at 93% of physical capacity, which was 2,004 vehicles. The short term situation will be exacerbated in the fall due to the loss of 280 spaces in the Athletic Parking Lots, while the CEE parking deck is being constructed.

Mr. Kaplan explained that they have planned for 396 new permanent parking spaces, as well as 100 temporary spaces. The temporary spaces will be removed in the spring and restored to natural landscaping. Of the new 396 permanent spaces, 174 are on the Coleman lot, the Forest Street lot, the new Woodland Hills lot, and the Sullivan lot, which is in Needham and not part of this permitting process. The new CEE deck will contain 137 spaces.

The Board asked how the college was planning to minimize demand. Mr. Kaplan said they are studying solutions such as a shuttle service to the T station, car pooling, four day work weeks, and limiting the number of student cars.

The Board commented that the plan to increase the number of parking lots appears to conflict with the stated goal of maintaining green space. Mr. Kaplan said that when they presented the Campus Facilities Plan, they stated their goal was to maintain as much green space as possible. Although they plan to construct some buildings on top of parking lots, some of the new buildings cannot be built on existing lots. However, a green swath will remain between the buildings and the streets.

Publisher's Hall Lot Discussion

Mr. Kolligian said that the Publisher's Hall Parking Lot will be a temporary parking lot. There will be a series of plantings to be located close to Forest Street, which will be removed when the parking lot is removed. No mature trees in and around the proposed lot will be removed. The Operations & Management Plan provides for scheduled visual inspections for oil spills, dust, watering, and maintenance of striping.

The Board asked if any borings had been done in this location as drainage in the area will be compromised if the subsurface was composed of glacial till. Mr. Kolligian said that the filter fabric laid down beneath the graveled top layer is porous, and the lot will be in place for only four months.

The Board asked about fire protection. Mr. Kolligian said there is an existing fire hydrant outside of Nichols Hall. The Fire Department has requested that the area around the hydrant be maintained.

The Board asked if the maneuvering aisles were 24 feet, and if not, 24 foot aisles would be required. The Board questioned how the lot would be lit. Mr. Kolligian responded that there are some existing walkway lights which will be maintained. There is also an existing light outside Publisher's Hall. No permanent lighting fixtures will be installed. The lot is to be used for student parking. There is a possibility that the

ZBA 2001-40
Petition of Babson College
Publisher's Hall Parking Lot
Babson College Campus

RECEIVED
TOWN ENGINEER'S OFFICE
TOWN ENGINEER STOP OFFICE
WELLESLEY MA 02482
AUG 11 8:11

entrance from Tomaso Road will be shifted to the south. The Board stated that if this occurred, a revised plan must be submitted to the Board showing the reconfiguration of the entrance.

No other person present had any comment on the petition.

Statement of Facts

The subject property is located in the northwest portion of the Babson Campus near Forest Street, in an Educational District and a Water Supply Protection District.

The petitioner is requesting Site Plan Approval for construction of Publisher's Hall Parking Lot, a 26,850 square foot temporary parking lot containing 70 spaces for use from August 1, 2001 to December 1, 2001. Restoration of the 26,850 square foot lot to grassed area will be done in Spring 2002. The lot will be accessed from internal campus driveways.

Stormwater runoff will flow to a low area adjacent to Forest Street, as it does under existing conditions, where it will percolate into the ground.

The following plans were submitted: Parking Lot Expansion Plan (5 of 7) dated 4/18/01, revised 4/23/01, revised 4/26/01, revised 6/12/01; Parking Lot Details Plan (6 of 7) dated 4/18/01, revised 4/26/01, revised 6/12/01; Parking Lot Details Plan (7 of 7) dated 4/18/01, revised 4/26/01, revised 6/12/01, all stamped by Gregory M. Valiton, Registered Professional Engineer.

The following information was submitted: Official Development Prospectus, Parking Study prepared by TEPP LC dated June, 2001; Project Narrative, letter Report of EcoTec, Inc. to Andrews Survey & Engineering, Inc.; and Letter from Andrews Survey & Engineering to DPW dated June 12, 2001.

On May 10, 2001, the Design Review Board reviewed the project and voted to recommend acceptance of the petition by the Board of Appeals.

On May 31, 2001, the Wetlands Protection Committee issued an Order of Conditions (DEP 324-356) for the proposed lot.

All materials and plans were also sent to the Planning Board, Wetlands Protection Committee, Town Engineer, Board of Health and the Fire Chief, as required pursuant to Section XVIA of the Zoning Bylaw. Written responses from each of the above were received and are on file in the office of the Board of Appeals.

On June 5, 2001, the Planning Board reviewed the petition. The Board had no objections and supported the recommendations of the Design Review Board.

Petition of Babson College
Publisher's Hall Parking Lot
Babson College Campus

RECEIVED
TOWN CLERK'S OFFICE
WELLESLEY MA 02482

2001 JUL 11 A 8:11

Decision

This Authority has made a careful study of the materials submitted and the information presented at the hearing. The proposed 26,850 square foot temporary Publisher's Hall Parking Lot containing 70 spaces, constitutes a Major Construction Project pursuant to Section XVIA of the Zoning Bylaw because it involves grading or regarding of land to planned elevations, and removal or disturbance of the existing vegetative cover over an area of 5,000 or more square feet.

It is the opinion of this Authority that the proposed plans for the construction of the temporary Publisher's Hall Parking Lot, as listed in the Statement of Facts, with required revisions, comply with the Zoning Bylaws of the Town, protect the safety, convenience and welfare of the public, minimize additional congestion in public and private ways and insure adequate protection for water, sewerage and drainage. Furthermore, compliance with Section VII, Section XVI, Section XXI and Section XXII of the Zoning Bylaw is met.

Site Plan Approval is granted, as voted unanimously by this Authority at the Public Hearing pursuant to Section XVIA of the Zoning Bylaw, subject to the conditions attached hereto as Addendum A.

APPEALS FROM THIS DECISION,
IF ANY, SHALL BE MADE PURSUANT
TO GENERAL LAWS, CHAPTER 40A,
SECTION 17, AND SHALL BE FILED
WITHIN 20 DAYS AFTER THE DATE
OF FILING OF THIS DECISION IN
THE OFFICE OF THE TOWN CLERK.

Cc: Planning Board
Doug Stewart, Assistant Town Engineer
Inspector of Buildings

Kendall P. Bates, Chairman

Richard L. Seegel

Cynthia S. Hibbard

ADDENDUM A

RECEIVED
TOWN CLERK'S OFFICE
WELLESLEY MA 02482

1. All work shall be performed in accordance with the last revisions on the submitted plans to be filed in the office of the Board of Appeals.
2. All design and construction shall comply with all applicable state and local codes.
3. Prior to construction, soil testing at the location of the proposed Cultec recharger units shall be performed. Test logs and percolation test results shall be submitted to the Engineering Division of the Department of Public Works, and the design of the recharger units be adjusted, if necessary.
4. The temporary parking lot containing 70 spaces shall be closed no later than December 1, 2001 and restored to a natural condition as soon as possible in Spring 2002. When the temporary surface is removed, the sod beneath the filter fabric shall also be removed and replaced with clean fill and new sod.
5. The Order of Conditions (DEP 324-356) issued by the Wetlands Protection Committee on May 31, 2001 is hereby incorporated into this decision.
6. Visual inspection for oil spills, dust and watering shall take place according to the schedule in the Operation and Maintenance Plan. If oil spills are detected, immediate remediation shall take place.
7. All parking spaces with painted lines shall be maintained at all times so no additional cars can park illegally blocking fire apparatus full access to each lane.
8. All maneuvering aisles shall have a width of 24 feet and all turning radii at interior corners shall have a minimum of 20 feet.
9. The bush at the right corner of the Nichols building to the right of the existing hydrant shall be removed and the area around said hydrant shall be maintained.
10. All requirements of the Town of Wellesley Fire Department shall be met.
11. All requirements of the Department of Public Works shall be met, including, but not limited to the requirement that water, sewer and electric connections, together with drainage connections be made in accordance with DPW standards and installed and maintained at no cost to the Town of Wellesley.
12. Upon completion of the project, a complete set of Site Utility Plans shall be submitted to the Department of Public Works.