

TOWN OF WELLESLEY, MASSACHUSETTS

FACILITIES MAINTENANCE DEPARTMENT

dgariepy@wellesleyma.gov

Fax (781) 446-6207

May 28, 2013

ADDENDUM No. 1

INVITATION FOR BID #WFMD-FY14-002

School Door Replacement Project

THIS ADDENDUM IS TO: **Change the Bid Opening Date and Answer the following Questions/Items from Pre-Bid Meeting:**

REVISED BID OPENING DATE: MAY 31, 2013 AT 11:00 AM

QUESTIONS

Q1. Will the existing corroded steel door frame for Door No. 5 at the Middle School remain?

A1. No – it will be removed and replaced with a new aluminum frame. See revisions to the Door Schedule below.

Q2. There is a typographical error on the cover page of the Project Manual, as it indicates the Bid Opening Date was May 30, 2012 – rather than 2013. Will this be addressed via addendum?

A2. Yes – see Addendum No. 1.

DRAWING CHANGES

Item 1-1

Door Schedule Drawing:

For Door No. 5, in the “Frame” column, **DELETE** "install within existing openings" and **REPLACE** with "SL- 260". In the last column (“Notes”), **ADD** “, replace existing corroded frame”.

All other terms and conditions of this bid remain unchanged.

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM.

Thank you.



Joseph F. McDonough, P.E.
Director of Facilities Maintenance Department