



Massachusetts Department of Environmental Protection
Bureau of Water Resources – Drinking Water Program

PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS) MAXIMUM
CONTAMINANT LIMIT (MCL) NOTICE OF NONCOMPLIANCE (NON)
With Violation Response/Compliance Schedule Approval (CSA) Form
M.G.L. c. 21A, § 16, 310 CMR 5.00

Attention: Public Water Supplier

A General Information

William Shaughnessy, Superintendent

CITY/TOWN: Wellesley

Wellesley Water Division
20 Municipal Way
Wellesley, MA 02481

PWS ID # 3317000

CLASS: COM

ENF DOC#: 00011460

B Location Where Noncompliance Occurred

Wellesley Water Division, 20 Municipal Way, Wellesley MA 02481

- Morses Pond Water Treatment Facility 3317000-03T

C Description of Violations under M.G.L. c. 111, §§159-160 and 310 CMR 22.00

The Department of Environmental Protection (MassDEP) Drinking Water Program has determined that you are in violation of the Per- and Polyfluoroalkyl Substances Rule for the following checked contaminant(s) and monitoring period(s):

Table 1- PFAS 6

	Contaminant	Monitoring Period(s)
<input checked="" type="checkbox"/>	Per- and Polyfluoroalkyl Substances - PFAS6 (sum of the concentrations of the six contaminants listed below) Perfluorooctane Sulfonic Acid (PFOS) Perfluorooctanoic Acid (PFOA) Perfluorohexane Sulfonic Acid (PFHxS) Perfluorononanoic Acid (PFNA) Perfluoroheptanoic Acid (PFHpA) Perfluorodecanoic Acid (PFDA)	2 nd Quarter 2021

Below is a description of the regulation(s) you have violated.

PFAS6 - MAXIMUM CONTAMINANT LEVEL

Your public water system violated the maximum contaminant level (MCL) specified in 310 CMR 22.07G(3)(d) for PFAS6 during the monitoring period(s) listed in Table 1 above.

D Action to Be Taken, and the Deadline for Taking Such Action

1. By June 19, 2021, provide Public Education and Public Notice to your customers in accordance with the provisions of 310 CMR 22.07G(7)(e), 310 CMR 22.07G(11), and 310 CMR 22.16.
2. By July 6, 2021, submit to MassDEP for its review and approval a written proposal setting forth how and when you propose to come into compliance with the requirements cited in Section C of this NON, by completing and

submitting the attached PFAS Response/Compliance Schedule Approval Form (“compliance plan”) and conducting all required public notice. To return to compliance, you must implement the compliance plan, including the schedule for completing the activities proposed, as approved by MassDEP. If you determine that you need additional time to complete and submit the compliance plan, you may request an extension before the submission deadline by contacting Amy LaPusata at 617-721-0160 or by email at amy.lapusata@mass.gov.

E *Important Information*

If you, the Supplier of Water, fail to take any action MassDEP now wants you to take by the prescribed deadline, or if you otherwise fail to remain in compliance in the future with the applicable requirements, you could be subject to legal action, including, but not limited to, criminal prosecution, court-imposed civil penalties, or civil administrative penalties assessed by MassDEP. A civil administrative penalty may be assessed for every day from now on that you are in noncompliance with the requirements specified above. MassDEP reserves its right to exercise the full extent of its legal authority to obtain compliance with all applicable requirements.

Date: June 4, 2021

Rachel Freed

Rachel Freed

Deputy Regional Director

Northeast Regional Office

MassDEP Bureau of Water Resources

Enclosures:

NON CSA Response Form

cc: Boston OE, Boston DWP

BOH lizzo@wellesleyma.gov

Meghan Condon, Assistant Superintendent mcondon@wellesleyma.gov

Y/DWPArchive/PFAS-ENF-NONCSA-Wellesley-3317000-2021-06-04

Rev. 2021-4-27